## User's Manual

# Model VJH1 Isolator

**NTXUL** 

(Isolated Single-output and Isolated Dual-output Types)

Thank you for purchasing the JUXTA Signal Conditioner.
Please read through this manual before use for correct handling.



IM 77J01H01-01E 6th Edition Mar. 2020 (YK)

Yokogawa Electric Corporation

## **GENERAL**

This plug-in type isolator converts DC current or DC voltage signals into isolated DC current or DC voltage signals.

Yokogawa Electric Corporation

2-9-32, Naka-cho Musashino-shi, Tokyo 180-8750 Japan Phone: +81-422-52-7179 Facsimile: +81-422-52-6793

You can download the latest manuals from the following website

http://www.yokogawa.com/ns/juxta/im/

- With OOP: VJH1/C (Option code /C)
   When the load circuit opens (OOP: output open), input
   resistance increases rapidly to 48kΩ or more so as to detect
   the open state through the input device.
- With OOP (HART communication): VJH1/HC (Option code /HC)
   In addition to the load circuit open (OOP) detection function, HART communication signals are relayed bidirectionally with the field device and host device isolated.

# CAUTIONARY NOTES FOR SAFE USE OF THE PRODUCT

This User's Manual should be carefully read before installing and operating the product. Please keep this User's Manual for future reference.

For more information of the safety precautions, please refer to the "Precautions on the Use of the JUXTA Series (IM 77J01A00-91Z1)". The related manuals and general specifications are shown in the table below.

Doc. Name	Doc. Number		
Precautions on the Use of the JUXTA Series (User's Manual)	IM 77J01A00-91Z1		
Model VJH1 Isolator (User's Manual)	IM 77J01H01-01E		
,	(This manual)		
Model VJH1 Isolator (General Specifications)	GS 77J01H01-01E		

User's manuals in the above table are essential parts of the product; keep it in a safe place for future reference.

This manual is intended for the following personnel;

- Engineers responsible for installation, wiring, and maintenance of the equipment.
- Personnel responsible for normal daily operation of the equipment.

The following symbol is used on the product and in this manual to ensure safe usage.



## **WARNING**

Calls attention to actions or conditions that could cause serious or fatal injury to the user, and indicates precautions that should be taken to prevent such occurrences.



## **CAUTION**

Calls attention to actions or conditions that could cause injury to the user or damage to the instrument or property and indicates precautions that should be taken to prevent such occurrences.

## CHECKING PRODUCT SPECIFICATIONS AND PACKAGE

#### (1) Checking the Model and Product Specifications

Check that the model and specifications indicated on the nameplate attached to the main unit are as ordered.

#### (2) Packaged Items

Check that the package contains the following items:

VJH1: 1 unit

Standard Accessories:

- Tag number label: 1 sheet
- Shunt resistor (for current input \*): 1 piece
   \* Excluding option codes /C and /HC.
- User's manual (IM 77J01H01-01E, this manual): 1 copy
- User's manual (IM 77J01A00-91Z1): 1 copy

## **MODEL AND SUFFIX CODES**

Model Suffix codes Description										
VJH1				-x			0	/x	Isolator	
Fixed code		Ĥ			_	_	Ť		Always -0	
Output 1							1 output			
							2 outputs			
Power supply 6 7				100-240 V AC/DC (*1)						
				15-30 V DC (*2)						
-A -B					4 to 20 mA DC					
					2 to 10 mA DC					
					1 to 5 mA DC					
-C -D -E				0 to 20 mA DC						
					0 to 16 mA DC					
				-F			0 to 10 mA DC			
-F -G					0 to 1 mA DC					
				-H					10 to 50 mA DC	
Input signal				0 to 10 mV DC						
				-2					0 to 100 mV DC	
				-3	$\vdash$				0 to 1 V DC	
				-4					0 to 10 V DC	
				-5	$\vdash$				0 to 5 V DC	
			-6					1 to 5 V DC		
				-7					-10 to +10 V DC	
				- <i>z</i>					Custom order (DC voltage/DC current)	
-Z   A							4 to 20 mA DC			
					В				2 to 10 mA DC	
					c				1 to 5 mA DC	
					D				0 to 20 mA DC	
					E				0 to 16 mA DC	
					F				0 to 10 mA DC	
					Ġ				0 to 1 mA DC	
Output-1 s	ians	al			1				0 to 10 mV DC	
Output-13	ignic	aı			2				0 to 100 mV DC	
					3		+		0 to 1 V DC	
4					0 to 10 V DC					
5							0 to 5 V DC			
							1 to 5 V DC			
7 7				-10 to +10 V DC						
					Custom order (DC voltage/DC currer					
<del></del>				Α			4 to 20 mA DC			
Output-2 signal					1 to 5 V DC					
					No output-2					
			$\vdash$		Custom order (DC voltage/DC current)					
			0		Always 0					
Option				/SN	No socket (with socket if not specified)					
				/C0	Coating (*3)					
				/FB	Fuse bypass (*3)					
				/FB	With OOP (*4) (*5)					
*1: Operating range: 95 to 264\/						_		/HC	With OOP (HART communication) (*4) (*5)	

- \*1: Operating range: 85 to 264V
- \*2: Operating range: 12 to 36V
- \*3: When option code /C0 or /FB is specified, the conformity to the safety and EMC standards is excluded. CE marking is not applicable.
- \*4: When the option code /C or /HC is specified, only the input signal code "A" (4 to 20 mA DC) can be specified, and the output-1 signal code can be specified only "A" (4 to 20 mA DC).
- \*5: Only output-1 is supported.

## 1. MOUNTING METHOD




## **CAUTION**

- Plug/disconnect the main unit into/from the socket vertically to the socket face. Otherwise the terminals may bend and it may cause bad contact.
- The converter shall not tilt 5 degrees or more in either direction when installed.
- When the converter is not connected to the socket, it is necessary to protect the socket against ingress of dust to the connector part.
- Keep this product in a conductive bag when plugged out, during transport or storage.


## 1.1 Wall Mounting

Loosen the main unit-fixing screw of the product and pull out the main unit from the socket. Fix the socket on the wall with screws. Next, insert the main unit into the socket and fasten the main unit with the main unit-fixing screw.



## 1.2 DIN Rail Mounting

Insert a DIN rail into the upper part of the DIN rail groove on the rear of the socket, and then slide the slide lock at the lower part of the socket upwards until the socket is fixed into position as shown below.



## 1.3 Mounting Using a Multi-mounting Base

When using a multi-mounting base, see the User's Manual for VJCE-01A (VJ Mounting Base for communication) (IM 77J01C51-11E).

#### 1.4 Using a Duct

2

When using a wiring duct, install the duct at leaset 30 mm away from the top and bottom faces of the main unit.

## 2. INSTALLATION LOCATION

- Avoid the following environments for installation locations: Areas with vibrations, corrosive gases, dust, water, oil, solvents, direct sunlight, radiation, a strong electric field, and/or a strong magnetic field, direct radiant heat, wind, temperature fluctuation, 2000 m or more above sea level.
- If there is any risk of a surge being induced into the power line and/or signal lines due to lightning or other factors, a dedicated lightning arrester should be used as protection for both this unit and a field-installed device.
- Operating temperature/humidity range: -10 to 55°C (-10 to 45°C for side-by-side mounting\*)/5 to 90%RH (no condensation)
  - \* If the previous model (style S3.xx earlier) is installed together, the ambient temperature is 0 to 40°C.
- Continuous vibration: (at 5 to 9 Hz) Half amplitude of 3 mm or less (at 9 to 150 Hz) 9.8m/s² or less, 1 oct/min for 90 minutes each in the three axis directions
- Impact: 98 m/s<sup>2</sup> or less, 11 ms, 3 axes, 6 directions, 3 times each

IM 77J01H01-01E 6th Edition Mar. 29, 2020

## 3. EXTERNAL WIRING




## **WARNING**

- To avoid the risk of an electric shock, turn off the power supply and use a tester or similar device to ensure that no power is supplied to a cable to be connected, before carrying out wiring work.
- Do not operate the product in the presence of flammable or explosive gases or vapors. To do so is highly dangerous.
- Use of the product ignoring the specifications may cause overheating or damage. Before turning on the power, ensure the following:
  - Power supply voltage and input signal value applied to the product should meet the required specifications.
  - The external wiring to the terminals and wiring to ground are as specifications.

Wiring should be connected to the terminals on the socket of the product. The terminals for external connections are of M3 screws. Use crimp-on terminal lugs for connections to the terminals.

Recommended cables: A nominal cross-sectional area of 0.5 mm<sup>2</sup> or thicker for signal cables, and that of 1.25 mm<sup>2</sup> or thicker for power cables.



<External Receiving Resistor (Shunt Resistor) for Current Input>

	9	`	,			
Input ragne	Resistance	Part No.	Input ragne	Resistance	Part No.	
10 to 50 mA DC	100 Ω	E9786WD	2 to 10 mA DC	500 Ω	E9786WF	
4 to 20 mA DC		E9786WE	0 to 10 mA DC	300 12	Lorouvi	
0 to 20 mA DC	250 Ω		1 to 5 mA DC	- 1 kΩ	E9786WG	
0 to 16 mA DC			0 to 1 mA DC			

Note: Option code /C and /HC have a built-in receiving resistor. An external receiving resistor is not required.



## CAUTION

- Do not use output-2 for the isolated single-output type.
- The power line and input/output signal lines should be installed away from noise-generating sources.
   Other wise accuracy cannot be guaranteed.
- Make sure to earth ground the ground terminal through minimum resistance. The length and thickness of the grounding cable should be as short and thick as possible. Directly connect the lead from the ground terminal (terminal no. 8) of the product to the ground. Do not carry out daisychained inter-ground terminal wiring.
- The product is sensitive to static electricity; exercise care in operating it. Before you operate the product, touch a nearby metal part to discharge static electricity.
- If the ambient temperature is 50 °C or more, please use the cable that the rated temperature is 70 °C or more.

3

## 4. MAINTENANCE


The product starts running immediately when the power is turned on; however, it needs 10 to 15 minutes of warm-up before it meets the specified performance.

## 4.1 Calibration Apparatus


- A DC voltage/current standard (YOKOGAWA GS200 or the equivalent)
- A digital multimater (YOKOGAWA DM7560 or the equivalent)
- A precision resistor of 250  $\Omega$  ± 0.01%, 1 W

## **4.2 Calibration Procedure**

 Connect the instruments as shown below. First adjust the output-1 signal and then the output-2 signal.



- Use the DC voltage/current standard and apply input signals equivalent to 0, 25, 50, 75, and 100% of the input span to the product.
- Check to see the corresponding output voltages are 0, 25, 50, 75, and 100% respectively and within the specified accuracy rating. "R" is used for current output.
- If the output signals are out of the accuracy rating range, adjust the output signal level using the zero and span adjustment volumes on front face of the product.



IM 77J01H01-01E 6th Edition Mar. 29, 2020

## 5. SAFETY AND EMC STANDARDS

The following will be acquired.

Safety:

IÉC/EN 61010-1 compliance (CE), IEC/EN 61010-2-030 compliance (CE)

CAN/CSA C22.2 No.61010-1 compliance (CSA)

UL61010-1 (CSA NRTL/C)

Installation category II

Pollution degree 2

Measurement category O (other)

Rated measurement input voltage: 10 V DC max.


Rated transient overvoltage: 1500 V (\*)

\* This is a reference safety standard value for Measurement Category I of CSA/UL61010-1 and Measurement Category O of EN 61010-2-030. This value is not necessarily a guarantee of instrument performance.



#### **CAUTION**

This instrument is for Measurement Category O (other). Do not use it for measurements in locations falling under Measurement Categories II, III, and IV.



Meas categ		Description	Remarks		
0	(other)	For measurements performed on circuits not directly connected to MAINS.			
II	CAT.II	For measurements performed on circuits directly connected to the low-voltage installation.	Appliances, portable equipments, etc.		
III	CAT.III	For measurements performed in the building installation.	Distribution board, circuit breaker, etc.		
IV	CAT.IV	For measurements performed at the source of the low-voltage installation.	Overhead wire, cable systems, etc.		

## EMC standards:

CE marking:

EN 61326-1 Class A, Table 2

EN 61326-2-3

 $^\star$  The instrument continues to operate at a measurement accuracy of within  $\pm 20\%$  of the range during testing.

EN 55011 Class A Group 1

EN 61000-3-2 Class A

EN 61000-3-3

 EMC Regulatory Arrangement in Australia and New Zealand (RCM):

EN 55011 Class A, Group 1

KC marking:

Electromagnetic wave interference prevention standard, electromagnetic wave protection standard compliance



## **CAUTION**

Caution to comply with EMC standards: When operating this instrument by external power supply, use an independent power unit conforming to CE-marking. Be sure to use the lightning arrester to comply EMC standards.

Note: When option code /C0 or /FB is specified, the conformity to the safety and EMC standards is excluded.

## 6. ENVIRONMENT STANDARD

RoHS Directive: EN 50581

(However, when option code /C0 or /FB is specified, CE marking is not applicable because the product does not comply with the Safety and EMC standards.)

## 7. TRANSPORT AND STORAGE CONDITIONS

- Temperature: -25 to 70°C
- Temperature change rate: 20°C per hour or less
- Humidity: 5 to 95%RH (no condensation)



## **CAUTION**

Keep this product in a conductive bag when plugged out, during transport or storage.

IM 77J01H01-01E 6th Edition Mar. 29, 2020