

### Revision List

referred to on Certificate No.: 968/FSP 1199.00/15

Product Tested: Pressure transmitter

EJX A Series and J Series, EJA E Series and J Series

| Type Designation  | Description   | Hardware Revision | Software Revision | Report-No.:        | Certification Status |
|---|---|-------------------|-------------------|--------------------|----------------------|
| EJX110A, EJX110J, EJA110E, EJA110J,<br>EJX120A, EJX120J, EJA120E, EJA120J,<br>EJX130A, EJX130J, EJA130E, EJA130J,<br>EJX310A, EJX310J, EJA310E, EJA310J | Differential Pressure Transmitters<br>4mA–20mA output and Integral digital output                 | 1.0               | 1.04              | 968/FSP 1199.00/15 | Valid                |
|   | Differential Pressure Transmitters<br>4mA–20mA output   | 1.1               | 3.01              | 968/FSP 1199.00/15 | Valid                |
| EJX115A, EJX115J, EJA115E, EJA115J  | Low Flow Transmitter<br>4mA–20mA output and Integral digital output                               | 1.0               | 1.04              | 968/FSP 1199.00/15 | Valid                |
|   | Low Flow Transmitter<br>4mA–20mA output   | 1.1               | 3.01              | 968/FSP 1199.00/15 | Valid                |
| EJX118A, EJX118J, EJA118E, EJA118J  | Diaphragm Sealed Differential Pressure Transmitter<br>4mA–20mA output and Integral digital output | 1.0               | 1.04              | 968/FSP 1199.00/15 | Valid                |
|   | Diaphragm Sealed Differential Pressure Transmitter<br>4mA–20mA output                             | 1.1               | 3.01              | 968/FSP 1199.00/15 | Valid                |
| EJX117J, EJA117J  | Sanitary Type Differential Pressure Transmitter<br>4mA–20mA output and Integral digital output    | 1.0               | 1.04              | 968/FSP 1199.00/15 | Valid                |
|   | Sanitary Type Differential Pressure Transmitter<br>4mA–20mA output                                | 1.1               | 3.01              | 968/FSP 1199.00/15 | Valid                |
| EJX210A, EJX210J, EJA210E, EJA210J  | Flange Mounted Differential Pressure Transmitter<br>4mA–20mA output and Integral digital output   | 1.0               | 1.04              | 968/FSP 1199.00/15 | Valid                |
|   | Flange Mounted Differential Pressure Transmitter<br>4mA–20mA output                               | 1.1               | 3.01              | 968/FSP 1199.00/15 | Valid                |

### Revision List

referred to on Certificate No.: 968/FSP 1199.00/15

Product Tested: Pressure transmitter

EJX A Series and J Series, EJA E Series and J Series

|   |  |     |      |                    |       |
|---|--|-----|------|--------------------|-------|
| EJX213J, EJA213J  | Sanitary Type Liquid Level Transmitter<br>4mA–20mA output and Integral digital output      | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|   | Sanitary Type Liquid Level Transmitter<br>4mA–20mA output                                  | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX430A, EJX430J, EJA430E, EJA430J,<br>EJX440A, EJX440J, EJA440E, EJA440J | Gauge Pressure Transmitter<br>4mA–20mA output and Integral digital output                  | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|   | Gauge Pressure Transmitter<br>4mA–20mA output  | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX438A, EJX438J, EJA438E, EJA438J  | Diaphragm Sealed Gauge Pressure Transmitter<br>4mA–20mA output and Integral digital output | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|   | Diaphragm Sealed Gauge Pressure Transmitter<br>4mA–20mA output                             | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX510A, EJX510J, EJA510E, EJA510J  | Absolute Pressure Transmitter<br>4mA–20mA output and Integral digital output               | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|   | Absolute Pressure Transmitter<br>4mA–20mA output   | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX530A, EJX530J, EJA530E, EJA530J  | Gauge Pressure Transmitter<br>4mA–20mA output and Integral digital output                  | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|   | Gauge Pressure Transmitter<br>4mA–20mA output  | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX533J, EJA533J  | Sanitary Type Gauge Pressure Transmitter<br>4mA–20mA output and Integral digital output    | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |

### Revision List

referred to on Certificate No.: 968/FSP 1199.00/15

Product Tested: Pressure transmitter

EJX A Series and J Series, EJA E Series and J Series

|                  |  |     |      |                    |       |
|------------------|--|-----|------|--------------------|-------|
|                  | Sanitary Type Gauge Pressure Transmitter<br>4mA–20mA output                  | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX610A, EJA610E | Absolute Pressure Transmitter<br>4mA–20mA output and Integral digital output | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|                  | Absolute Pressure Transmitter<br>4mA–20mA output                             | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX630A, EJA630E | Gauge Pressure Transmitter<br>4mA–20mA output and Integral digital output    | 1.0 | 1.04 | 968/FSP 1199.00/15 | Valid |
|                  | Gauge Pressure Transmitter<br>4mA–20mA output                                | 1.1 | 3.01 | 968/FSP 1199.00/15 | Valid |
| EJX910A, EJX930A | Multivariable Transmitter<br>4mA–20mA output and Integral digital output     | 1.0 | 1.02 | 968/FSP 1199.00/15 | Valid |
|                  |  |     | 3.01 | 968/FSP 1199.00/15 | Valid |

### Safety Manual / User documentation

| Document No.                  | Description  | Report-No.:        | Certification Status |
|-------------------------------|--|--------------------|----------------------|
| IM 01C25T01-06EN, 6th Edition | Safety manual, Safety Instrumented Systems Installation for EJX A Series and J Series, EJA E Series and J Series | 968/FSP 1199.00/15 | Valid                |
| IM 01C25R02-01E, 7th Edition  |  |                    |                      |

### Document Revision:

| Date       | Rev. | Description / Changes                                     | Author         |
|------------|------|---|----------------|
| 2015-11-30 | 1.0  | Initial creation, based on Report-No.: 968/FSP 1199.00/15 | Yuki Nishihata |